



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/EH/2023/SZ/ 229

Dated 04/05/2023

To,

Sh. Sanjay Tyagi (Owner)  
M/s Woodland Affairs (Utkrisht Hospitality  
Pvt. Ltd.) DDA Lake and Woodland Park S ,  
Jheel Park, Hari Nagar, New Delhi-110064.

**Sub:** - Regarding grant of NOC from fire safety point of view in r/o M/s Woodland Affairs (Utkrisht Hospitality Pvt. Ltd.) DDA Lake and Woodland Park S , Jheel Park, Hari Nagar, New Delhi-110064.

Sir,

Please refer to Online ID No. 2023030102853 Dated 10/04/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of the above-mentioned assembly building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. First Aid Hose Reels not provided.
2. MOEFA system not provided.
3. Down comer system not provided.
4. Fire Pump having 450 LPM with 40 M head not provided.
5. Over head water tank 20, 000 liters not provided.
6. Exits signage's are not provided.
7. Standby power supply not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Ajul Garg)

Director

Delhi Fire Service

9/05/23

Copy to:-

1. The Joint Commissioner of Police, 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064.