



c6

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2023/NDZ/ 238

Dated: 12/05/2023

To

Mr. Arun Rana  
FlyLeaf Hospitality LLP Restaurant,  
Shop NO. C-50, First Floor, Preet Vihar,  
New Delhi-110092.

Subject:- Fire Safety Certificate in r/o FlyLeaf Hospitality, LLP Restaurant Shop NO. C-50, First Floor, Preet Vihar, New Delhi-110092.

Sir,

This has a reference to your online MHA application No. 2023042907753 Dated 29/04/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Mr. Arun Rana on dated 04/05/2023. The building comprised of Basement, ground, first, second, third and barsati. Proposed eating house is on first floor only.

Following shortcomings were observed during time of inspection :

1. Two number of staircases of width 1.50 meter & 1.15 meter are provided against requirement of 1.50 meter width each.
2. One door of width 1.50 meter & two door of width 01 meter are provided against requirement of two door of 1.50 meter width each.
3. terrace fire pump of capacity 450 LPM with 40 meter head not provided.
4. Internal Hydrant and Hose reel provided but not functional.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate can not be considered at this stage. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:- for information.

1. The Joint Commissioner (Lic.) 1st Floor Police Station Defence Colony, New Delhi.  
w.r.t. to MHA ID 2023042907753