



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/ 977

DATED: 15/05/2023

To,

Sh. K. Sankar Lingum Ganesh,  
Centre for Cultural Resources and Training,  
Plot 15/A, Sector - 7,  
Dwarka, New Delhi - 110075.

**Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Auditorium of Centre for Cultural Resources and Training Located at Plot 15/A, Sector - 7, Dwarka, New Delhi - 110075.**

Sir,

Please refer to your letter No. CCRT/11013/11/2018/2122, dated 19/04/2023 on the subject cited above. In this connection it is to inform you that the above said premises was re-inspected by the officers concerned of this department on 08/05/2023 in the presence of Sh. K. Sankar Lingum Ganesh for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Some exhaust system in basement and auditorium found nonfunctional/ removed.
2. Smoke Detector found provided but nonfunctional.
3. MOEFA found nonfunctional.
4. Hose reel & hydrant are found removed in basement and it should be extended to left out area.
5. Sprinkler system found removed in basement.
6. Hoses and Branches found missing at some floors/ places.
7. Stand by diesel pump found nonfunctional in auto mode.
8. Exit signage found removed at some places.
9. Seating arrangement found not provided as per cinematography act.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)  
(Director)

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.