

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2023/1003

Dated.16.05.2023

To,

Sh. B.K. Singh,
Secretary,
Antriksh Bhawan,
22 K.G. Marg, New Delhi.

Sub:- Regarding renewal of FSC in r/o Antriksh Bhawan, 22 K.G. Marg, New Delhi.

Sir,

This has a reference to your Nil dated 17.04.2023, on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 02/05/2023 in the presence of Sh. Charanjeet Singh (Estate Officer) and the following shortcomings were observed:-

1. Fire check doors not provided at 16th floor.
2. Hose reel not provided at first floor.
3. Detectors found non functional at some offices.
4. Lift signages "not to use lift in case of fire" not provided.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, New Delhi Municipal Council, Palika Kendra, New Delhi.
2. Sh. B.K. Singh (Secretary), Antriksh Bhawan, 22, K.G. Marg, New Delhi.