

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO F-6/DFS/MS/GH/2023/206

Dated 15/05/2023

To

The Joint Commissioner of Police / Lic-Branch  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi 110049

**Sub:** - Regarding issuance of fire safety certificate in t/o M/s CABANA HOTEL, (A unit of Shree Prema) R-23, Greater Kailash-I New Delhi- 110048


Sir,

This has reference to your MHA Portal ID 2023040405220 dated 10/04/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08/05/2023 in the presence of Mr. Uday (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Smoke Ventilation system not provided as per clause 7.31 of UBBL 2016.
- 2 Carbon Monoxide detector provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

9/5