

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/SZ/2023/ 1009

Dated: 16/05/2023

To,

Sh. Pappu Kumar Rajak (D/C)
CRPF HQ Building at CGO Complex,
Lodhi Road Block No.1,
New Delhi.

Subject: Application of Renewal r/o CRPF HQR Building at CGO Complex Lodhi Road Block No. 1, New Delhi from Fire Safety and means of escape point of view.

Sir,

Please refer to your letter received through Outdoor dairy application no. 1086 dated 24/04/2023 on the subject noted above, in this connection, it is to inform you that the said premises was re- inspected by the officer concerned of this department on 06/05/2023 in the presence of (inspector) Ashok Jhakar and observed that Business Building on ground + 5 Upper floors only.

Following shortcomings were observed during the time of inspection:-

1. Lift signage is not provided at ground floor.
2. Terrace hydrant is not functional.
3. Electrical shaft not shield at upper floor.
4. MCP Provided but not functional.
5. Loose/hanging wiring seen at some places of building it shall be through conduit/cable tray.
6. Ventilation/Smoke management not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR.

Delhi Fire Service

o/c 8E

Copy to:-

1. Joint Commissioner of Police (Lic), 1st Floor, PS Defence colony, New Delhi-110049.