

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2023/207

Dated 15/05/2023

To

The Joint Commissioner of Police / Lic-Branch
1st floor, Police Station,
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Golden leaf, A-1/296, Safdarjung Enclave, New Delhi 110029

Sir,

This has reference to your MHA Portal ID 2023042407279 dated 26.04.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08/05/2023 in the presence of Sh Lokesh Pahwa (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

- 1 The First Aid hose reel provided but found not working.
- 2 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 3 Fire fighting pumps are not working.
- 4 Exit signage found removed at static locations.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/d