



C 227
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/NDZ/EH/241

Dated: 12/05/2023

To

Authorized Signatory,
Kiah Associates, Shop No. 35/1,
B-Block, Guru Nanak Pura,
Laxmi Nagar, Delhi-110092.

Subject:- Regarding "Fire Safety Certificate" from fire safety point of view in r/o Kiah Associates, Shop No. 35/1, B-Block, Guru Nanak Pura, Laxmi Nagar, Delhi-110092.

Sir,


This has a reference to your MHA portal application No.2023041406440 Dated 20/04/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 02/05/2023 in the presence of Sh. Saksham and observed that building comprised of Ground & First Floor only but restaurant running on Ground Floor.

Following shortcoming were observed during the time of inspection :

1. Fire Check doors not provided.
2. Two Doors of width 1.10 mtr & 1.80 mtr are provided against required width of 1.50mtr each.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Joint Commissioner of Police (Lic.), 1st Floor, P. S. Defence Colony, New Delhi-24 w.r.t. MHA portal application No.2023041406440 Dated 20/04/2023.