



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
 आज़ादी का
 अमृत महोत्सव

No: F.6/DFS/MS/School/WZ/2023/248

Dated: 17/05/2023

To

The Principal,
 Maharaja Agarsain Public School,
 Ashok Vihar Phase-IV,
 New Delhi- 110052.

Sub:- Regarding renewal of Fire Safety Certificate in r/o Maharaja Agarsain Public School, Ashok Vihar phase- IV, Delhi- 110052.

Sir,

This is in reference to your letter No. MAPS/2023/90 dated 06.04.2023 on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department in the presence of Sh. Chandan, Caretaker, on 08.05.2023 to check the status of the fire safety arrangements already provided in the school building.

During the course of inspection, it was observed that the school building is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, hose reel hose, PA system, terrace pump capacity 900 LPM, overhead water storage tank capacity 5000 lts, sprinkler system in basement floor etc. found provided. However, following shortcomings were observed: -

1. Classrooms & Auditorium are running in the basement floor, which is not permissible as per Building Bye-Laws.
2. Additional overhead water tank capacity 10,000 lts is required.
3. Terrace pump found not on auto mode.
4. Exit signages found removed at some places.
5. Ventilation system in basement floor found removed.

In view of the above shortcomings, the request for renewal of fire safety certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this regard.

Yours faithfully

(Atul Garg)
 Director

Copy to: -

1. The Principal, Maharaja Agarsain Public School, Ashok Vihar phase- IV, Delhi-110052.
2. The Directorate of Education, GNCT of Delhi, Old Secretariat, Delhi- 110054.