

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/254

Dated: 17/05/2023

To,

The Principal,
Nigam Utkrist Vidyalaya,
C-7, Suraj Kunj, Khesav Puram,
New Delhi-110035.

Sub: - Regarding Issuance of Fire Safety Certificate in r/o Nigam Utkrist Vidyalaya Located at C-7, Suraj Kunj, Khesav Puram, New Delhi-110035.

Sir,

Please refer to your letter received through Outdoor Diary No-469 dated 13/04/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 09/05/2023 in presence of Mrs. Sanju Aggarwal (Incharge) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running in Block - 01 comprised of Ground + 02 upper floors & Block -01 is used as district educational office comprised Ground + 1 upper floor. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First -Aid hose reels are provided but not functional.
2. Terrace Pump of 450lpm is provided but not on auto mode.
3. Overhead water storage tank of capacity of 10,000 ltrs is provided but not exclusively for fire fighting purpose.

In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


Atul Garg
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.