

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/SZ245

Dated: 15/05/2023

To,

The Manager,
Sainik Harsh Convent School,
A-19, Avtar Vihar, Mohan Garden,
Uttam Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Sainik Harsh Convent School, A-19, Avtar Vihar, Mohan Garden, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. Nil dated 20/03/2023 on the subject cited above. In this regard, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 04/05/2023 to see the compliance of the requisite fire safety measures Smt. Sunita Bhardwaj (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. An additional staircase shall be provided 1.5 m wide or extend the staircase of .90 m to 1.50 m.
2. Class rooms door size .90 m provided in place of 1.0 m at second floor.
3. Fire extinguishers are provided but not functional.
4. First aid Hose reel not provided at each floor level.
5. Fire pump having 450 lpm output at 40 meters head not provided at terrace level.
6. Overhead water storage tank 10,000 liters not provided.
7. Exit Signage's are not provided.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully,



(Atul Garg)

Director

Delhi Fire Service



Copy:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.