

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2023/215

Dated: 19/05/2023

To

The Owner/Occupier
M/s. Hotel Bharat Palace, 3/73 & 3/14,
Old Rajinder Nagar, New Delhi- 110060.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Hotel Bharat Palace, 3/73 & 3/74, Old Rajinder Nagar, New Delhi- 110060.

Sir,

Please refer to your Online Application No. 2023042907792 dated 01.05.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 10.05.2023 in the presence of Sh. A.P. Singh (Manager) to check the functionality of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus four upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check Doors are not provided.
2. Carbon Monoxide detectors found not provided.
3. MOFEA system found provided but not functional.
4. PA system found provided but not functional.
5. Terrace fire pump 450 LPM found provided but not functional.
6. 4th floor found in use at the time of inspection which is not allowed.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter no F6/DFS/MS/GH/SZ/2022/43 dated 24.01.2022, is immediately suspended. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi. 