

c 213

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/SZ/2023/HTL/16

Dated: 19/05/2023

To,

P.K Bishwal ,  
M/s Hotel Samrat (A Unit of ITDC, 50-B,  
Kautilya Marg,  
Chanakyapuri, New Delhi-21

**Subject: Inspection report of Renewal M/s Hotel Samrat (A Unit of ITDC) 50-B, Kautilya Marg, Chanakyapuri, New Delhi-21, from Fire Safety and means of escape point of view.**

Sir,

Please refer to your letter received through Outdoor dairy application no. 12579 dated 24/03/2023 on the subject noted above, in this connection, it is to inform you that the said premises was re- inspected by the officer concerned of this department on 04/05/2023 in the presence of P.K Bishwal (D.G.M) and observed that Hotel running on small Basement, lower ground, Upper ground + 6 Upper floors only.

Following shortcomings were observed during the time of inspection:-

1. One of the Staircase at 3<sup>rd</sup> floor found locked and blocked.
2. Fire check door found removed at some places.
3. Hose reel hose found defective in Basement.
4. Sprinkles found removed in left out are note is fixup some places in basement & ground floor level.
5. Manually call point are not functional at some place.
6. Fire fighting pump are not auto mode.
7. Overhead water storage tank found empty and under maintenance.
8. Ventilation System are not on auto mode it shall also be integrated with fire alarm system.
9. Some Part of 2<sup>nd</sup> floor are under renovation.
10. Wooden temporary office found erected at 5<sup>th</sup> floor level and encroachment seen at the time of visit.
11. Loose/hanging wiring seen at some places of building it shall be through conduit/cable tray.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, PS Defence colony, New Delhi-110049.