



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F-6/DFS/MS/EH/2023/265

Dated 19/05/2023

To

The Manager,
 Property No. F-14/12, Ground Floor,
 Model Town Part-II, Delhi-110009.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Jubilant Food Works Limited (Dominos Pizza Restaurant) located at Property No. F-14/12, Ground Floor, Model Town Part-II, Delhi-110009.

Sir,

This has reference to your online mha portal I.d No. 2023050308092 dated 03/05/2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 10/05/2023 in the presence of Mrs. Archana (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it is observed that the building/ premise is comprised of ground & 02 upper floors but (Restaurant is running at ground floor only). Your request for FSC is rejected under Rule 37 (3) due to following shortcomings

- 1 First aid hose reel hose provided but not functional and nozzle found missing
- 2 MOEFA provided but not functional at the time of inspection.
- 3 Internal hydrants provided but not functional.
- 4 Terrace level fire pumps capacity of 450lpm provided but not functional
- 5 Exit signage's found removed in the restaurant

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'J' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.

Yours faithfully/


 Anil Garg
 Director
 Ph: 011-23414000
 etc

Copy to:

1. The Dy. Commissioner of Police/Lie. 1st Floor, PS Defence Colony, New Delhi