

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/EH/2023/SZ/264

Dated 19/05/2023

To,

The Manager,
M/s KD FOODS, D-4, Second Floor,
Rajouri Garden, New Delhi-110027.

Sub: - Regarding grant of NOC from fire safety point of view in r/o M/s KD FOODS, D-4,
Second Floor, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to Online ID No. 2023042907804 dated 29/04/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of the above-mentioned assembly building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. Door size of restaurant 1.86 & 1.10 m provided in place of 2 m & 1.5 m.
2. Exits signage's are not provided.
3. Fire fighting system not provided in Kitchen area.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064.