

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2023/259

Dated: 18/05/2023

To

The Vice Principal,  
 Lions Vidya Mandir Secondary School,  
 (Behind Kashmir House) Kushak Lane,  
 New Delhi-110011

**Sub: Regarding renewal of Fire Safety Certificate in r/o Lions Vidya Mandir Secondary School, (Behind Kashmir House) Kushak Lane, New Delhi-110011**


Sir,

This has reference to your letter No. L.V.M/Fire/2023/1225 dated 02/05/2023, received through outdoor dairy No. 1559 dated 02.05.2023 on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 12.05.2023 in the presence of Sh. Pradeep Kumar (Vice Principal) to verify the compliance of shortcomings communicated vide this department letter of even No. 186 dated 16.03.2020. The shortcomings observed are as below:-

1. Hose reels found non-functional.
2. Internal hydrant non-functional.
3. Terrace level pump found non-functional.

In view of above shortcomings, the renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
 (Atul Garg)  
 Director  
 Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.