



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/EH/2023/NDZ/261

Dated: 19/05/2023

To,

Sh. Rohit Roy Show Sha Baazi Café and Restaurant Shop No. G-80, Third Floor, Main Vikas Marg, Preet Vihar, Delhi-110092.

Subject:- Online Application ID No 2023031803852 in r/o Show Sha Baazi Café and Restaurant located at Shop No. G-80, Third Floor, Main Vikas Marg, Preet Vihar, Delhi-110092. Sir.

With reference to your online MHA application No. 2023031803852 dated 20/03/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Mr. Jatin, on dated 19/04/2023. The building comprised of basement, ground plus three upper floors. Proposed eating house is on third floor. Following shortcomings were observed during the time of inspection.

- 1. Two number of staircase width 1.5 meter not provided.
- Kitchen should be segregated by the means of fire check door.
- 3. Two door of width 1.30 meter and 1.35 meter provided against the requirement of 1.50 meter
- Public Address System not provided.
- Smoke management system not provided.
- 6. Main pump of capacity 2280 LPM with 60 meter head, stand by diesel pump of capacity 2280 LPM with 60 meter head and Jockey pump of capacity of 180 LPM with 60 meter head not provided.
- Under ground water tank 1,00,000 liter not provided.
- Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

DEL'HI FIRE SERVICE

Copy to:-

The Joint Commissioner (Lic.)

1st floor Police Station Defence Colony, New Delhi w.r.to MHA ID 2023031803852 dated 20/03/2023