

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2023/268

DATED: 19/05/2023

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

The DCP Office District Dwarka,  
Sector -19, New Delhi.

**Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in M/s Singlas retail pvt ltd. Located at Plot no 232, Dwarka Sector - 9, New Delhi - 110075.**

Sir,

This is in reference to online application No. 2023050107880, dated -02/05/2023 the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 11/05/2023 in the presence of Sh. Shivam ( Employee).

During the course of inspection followings shortcoming are observed:-

1. Two stairs of 1.5m clear width for all the floors up to terrace are found not provided.
2. Two stairs of 1.5m clear width for basement are found not provided.
3. Two Exits of 1.5 M width for all the floors found not provided.
4. Fire check doors are found not provided.
5. Smoke exhaust system found not provided in basement.
6. MOEFA found provided but nonfunctional.
7. Sprinkler system in basement is provided but nonfunctional.
8. Main Pump & Standby pump of 2280 lpm at ground level found not provided.
9. Jockey pump of 180 lpm found not provided.
10. Two terrace pumps of 450 LPM are found not provided.
11. Hydrant & Hose Reels at each floor are found provided bur nonfunctional.
12. Terrace fire water tank of 10,000 ltrs found not provided.
13. Underground fire water tank of capacity 1,00,000 ltrs found not provided.
14. Exit signage found not provided.
15. Pressurization system for lift car & lift lobby found not provided.
16. Communication system from lift car to guard room found not provided.
17. Temporary shed found erected around the building, it must be removed.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

**Apart from this the restaurant is running without getting Fire safety Certificate. The owner/occupier is responsible for loss of life/ property, if any.**

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Manager M/s Singlas retail pvt ltd. Plot no 232, Dwarka Sector - 9, New Delhi - 110075.
2. The Deputy Health Officer, Municipal Corporation of Delhi, Public Health Department, Najafgarh Zone, Room No 408, 4<sup>th</sup> floor Zonal Building, Dhansa Stand, Najafgarh, New Delhi - 110043.