



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/257

Dated: 18 /05 /2023

To

The Manager
Suraj International School,
25 Foota Road, Shastri Park,
Nathupura, Burari, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Suraj International School at 25 Foota Road, Shastri Park, Phool Bagh Road, Nathupura, Burari, Delhi-110084.

Sir,

Please refer to your letter No. Nil dated 10.04.2023 received in this department vide outdoor dairy no 209 dated: 10.04.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 08.05.2023 to verify the fire safety measures issued vide NBC Part- IV and observed that the school premise is comprised of 02 blocks. First block is comprised of ground floor only & second block is comprised of ground plus first floor. At the time of inspection Sh. Arun Sehgal (Admin) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Only one staircase provided width of 1.50m against the requirements of 02 nos. staircases width of 1.50m each.
2. MOEFA system not provided.
3. Exit signage and floor signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage & rejected. You are requested to apply with complete building plans including fire and life safety provisions as per NBC Part- 2016 through building sanctioning authority for further consideration in the matter.

Yours faithfully

(Vijay Garg)
Director

Ph -011-23414000

de

Copy to:-

1. The Director, Education, Government of N.C.T. of Delhi - Old Sectt. Delhi - 110054.