

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/MN/2023/262

Dated: 19/05 /2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Subject: Issuance of Fire Safety Certificate in respect M/s. Tikka Junction (Tikka Junction Pvt. Ltd.) Located at Block.N.47, Kirti Nagar, New Delhi - 110015.

Sir,

Please refer to the online application Id No. 2023042307186 dated 24/04/2023 received through MHA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 06/05/2023 in the presence of Sh. Shivam Mishra to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at ground floor in a building comprised of Ground plus 2 upper floors. However the following shortcomings were observed.

1. Width of door size is provided 98 x 2mtr against requirement of 2 x 1.5mtr. 01 door of width 98cm is also provided running through kitchen which is not acceptable.
2. First Aid Hose Reel is not provided.
3. MOEFA is not provided.
4. Internal Hydrant is not provided.
5. Pumping arrangements capacity 450 lpm is not provided.
6. Overhead Water Storage tank of capacity 20,000 ltrs is not provided.
7. Exit Signage's are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier M/s. Tikka Junction (Tikka Junction Pvt. Ltd.) Located at Block.N.47, Kirti Nagar, New Delhi - 110015.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- (dhowest_zone@gmail.com)