

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/2023/college/22

Dated: 22/05/2023

To

Sh. P.V. Krishna Raja (Administrator),
M/s Delhi Music Society, 8, Nyaya Marg,
Chanakyapuri, New Delhi-110021

**Sub: Regarding issuance for Fire Safety Certificate in r/o M/s Delhi Music Society, 8,
Nyaya Marg, Chanakyapuri, New Delhi-110021**

Sir,

Please refer to your letter No. F. No. DMS/Fire/2022 dated 17/04/2023, received through outdoor dairy No. 784 dated 18.04.2023 on the subject cited above. In this connection, it is to inform you that the said premise was re-inspected by the officer concerned of this department on 12.05.2023 in your presence to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/College/2022/SZ/20 dated 26.05.2022.

The shortcoming observed is as below:-

1. The width of exit door (final exit) in hall at 2nd floor is still 1.40m against required width of 1.50m

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Chief Architect, Department of Architecture and Environ, New Delhi Municipal Council, Palika Kendra, New Delhi- 110001