



C-11  
7  
आशादीन  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/268

Dated: 24/05/2023

To,

The Principal/H.O.S,  
Govt. Sarvodaya Girls Sr. Sec. School,  
A- Block, Keshav Puram,  
New Delhi-110035.

**Sub: - Regarding renewal of fire safety certificate in r/o Govt. Sarvodaya Girls Sr. Sec. School Located at A- Block Keshav Puram, New Delhi - 110035.**

Sir,

Please refer to your Email dated 03/05/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 17/05/2023 in presence of Sh. Rakesh Gautam (H.O.S) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running Ground + 3 upper floors in a building comprised of Ground + 03 Upper Floors. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First Aid Hose Reels are provided but not functional.
2. Internal Hydrant is provided but not functional.
3. Terrace level pump capacity of 900lpm & 180lpm is provided not functional.
4. Overhead water storage tank is provided but found empty.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is not considered & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
Atul Garg  
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

2  
22/5/23  
29/5/23