

C/305

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2023/120

Dated: 01/06/2023

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Ishaan Residency situated at 19, Ansari Road, Daryaganj, New Delhi -02.

Sir,

This is in reference to online application I.D. no.2023051208791 dated 13.05.2023 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned from this department on 29.05.2023 in the presence T. C. Pathak (Manager) and it was observed that building is comprised of Basement + Ground + 05 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm found non functional.
2. MOEFA found non functional.
3. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Licensee,

M/s Ishaan Residency at 19, Ansari Road, Daryaganj, New Delhi -02.