

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2023/ 1153

Dated:- 01.06/2023

To

The Manager,
M/S ANSA Retail Pvt Ltd,
Ground Floor, R.K.Ashram Metro Station,
New Delhi.

Sub: **Regarding issuance of FSC in r/o M/S ANSA Retail Pvt Ltd, located at Ground Floor, R.K.Ashram Metro station, New Delhi, ID NO. 2023032304145 dated 18.05.23.**

Sir,

This has reference to online ID No. **2023032304145 dated 18.05.23** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 26/05/2023 in the presence of Mr. Vipin and following shortcomings were observed: -

1. First aid hose reel and hydrant systems are not provided.
2. MOEFA is not provided.
3. Terrace pump of 450 LPM is not provided.
4. Overhead fire water tank of 20,000 liter capacity is not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.