

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

F-6/DFS/MS/GH/2023/SZ/236

Dated 31/05/2023

To

The Joint Commissioner of Police / Lic-Branch  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi 110049

**Sub: -** Regarding issuance of fire safety certificate in r/o Hotel AARON CASTLE located at A-56, Kailash Colony, New Delhi-110048


Sir,

This has reference to your MHA Portal ID 2023041606573 Dated 19/04/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08/05/2023 in the presence of Ms. Priyanka (Front Office) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Fire check doors not provided as per clause 7.31 of UBBL 2016.
- 2 Smoke management system not provided in the upper floor as per clause 7.31 of UBBL 2016.
- 3 Carbon Monoxide detector provided but found not functional as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ANIL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

