

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2023/SZ/232

Dated 30/05 /2023

To  
The Joint Commissioner of Police  
Lic. (Branch), 1<sup>st</sup> floor, Police Station  
Defence Colony, New Delhi 110049

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s Hotel Viva Place at Plot No L-74, Gali No -7, Mahipalpur Extn. New Delhi 110037

Sir,

This has reference to MHA Portal ID No 2023040605499 dated 07/04/2023 & 2023032404188 dated 24/03/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23/05/2023 to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management not provided in upper floor of the building.
2. The occupancy of 4<sup>th</sup> floor is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:

1. M/s Hotel Viva Place at Plot No L-74, Gali No -7, Mahipalpur Extn. New Delhi 110037