

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2023/ 234

Dated: 31/05/2023

To,

The Owner/Occupier,
M/s. J.P. Inn guest house,
5/2, East Patel Nagar, New Delhi- 110008.

Subj: Regarding renewal of Fire Safety Certificate in respect of M/s. J.P. Inn guest house, 5/2, East Patel Nagar, New Delhi- 110008.

Sir,

Please refer to your Online email Id arks.office1@gmail.com dated 19.05.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 23.05.2023 in the presence of Sh. Umesh Tiwari (Manager) to check the functionality of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts, etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Terrace fire pump 450 LPM found provided but not functional.
2. Exit Signage found removed.
3. Basement and ground floor using under the Union Bank of India.


In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter No. F6/DFS/MS/GH/SZ/2021/227 dated 19.07.2021, is immediately suspended. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

O/C 

Copy to:-

The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor,
New Delhi.