



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/2023/SZ/EH/289

Dated: 30/05/2023

To,

Mr. Puneet Jain,
M/s Jubilant Foodworks Limited (Dominos Pizza),
G-24, 1st Floor, South Extension Part-I,
New Delhi- 110049.

Subject: Inspection report of Renewal M/s Jubilant Foodworks Limited (Dominos Pizza), G-24, 1st Floor, South Extension Part-I, New Delhi-110049, from Fire Safety and means of escape point of view.

Sir,


Please refer to your letter received through MHA portal ID No.-2023051609017 dated 17/05/2023 on the subject noted above, in this connection, it is to inform you that the said premises was re-inspected by the officer concerned of this department on 24/05/2023 in the presence of Sh. Krishan (Branch Manager) from fire safety point of view.

Following shortcomings were observed during the time of inspection:-

1. Single staircase of 1.10m width is provided against required two staircases having width of 1.5m each.
2. Single exit/door of 1.07m width is provided against required two exit/door having clear width of 1.5m each.
3. The required internal hydrant is not provided.
4. The overhead water storage tank of capacity approx. 5,000 Ltrs is provided against requirement of 20,000 Ltrs.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(APUL GARG)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer, South MCD, Public Health department, Green Park, Aurobindo Marg, New Delhi-110016.