

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2023/288

Dated: 31/05/2023

To,

The Principal,
Nav Jeevan Academy Senior Secondary School,
B Block, Madhu Vihar, Dwarka,
Sector-III, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Nav Jeevan Academy Senior Secondary School Located at B Block, Madhu Vihar, Dwarka Sector-III, New Delhi.

Sir,

Please refer to your Email dated 12/05/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned from 22/05/2023 in the presence of R.K Sharma (Manager) from fire safety point of view.

The following shortcomings were observed during the inspection:-

1. Smoke management system in basement found nonfunctional.
2. Hose reel hoses & hydrants found nonfunctional
3. Sprinkler system in basement found nonfunctional
4. PA system found nonfunctional.
5. Terrace pumps found nonfunctional.
6. Exit Signage found removed at some places.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.


Yours faithfully,


(Anil Garg)

Director

Delhi Fire Service

Copy to: - Directorate of Education Old Secretariat Delhi – 110054


W/c
25/5/23