

C-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2023/284

Dated: 30/05/2023

To,

The Principal,
Parkash Model School,
Mahavir Enclave Part III, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Parkash Model School Located at Mahavir Enclave Part III, New Delhi.

Sir,

Please refer to your letter No. PMS/2003/23/05 dated - 06/05/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned from this department on 20/05/2023 in the presence of Mr. Bhoop Singh (Manager) from fire safety point of view.

The following shortcomings were observed during the inspection:-

1. Hose reel hoses found nonfunctional.
2. PA system found nonfunctional.
3. Terrace pump of 220 lpm found nonfunctional.
4. Terrace tank of 2500 lpm found empty.
5. Exit Signage found removed at some places.
6. Dully filled form J & K & school details forms are not submitted.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to, - Directorate of Education Old Secretariat Delhi 110054

dc
a
110054
29/5/23