

201

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2023/238

Dated:-31/05/2023

To,

The Manager,
M/S Rama Deluxe Guest House,
2278-79, Gurudwara Road,
Karol Bagh, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Rama Deluxe Guest House, 2278-79, Gurudwara Road, Karol Bagh, New Delhi.

Sir,

This has reference to on line ID No. 2023040705672 dated 05.05.23, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 23/05/2023 in the presence of **Manager** and following shortcomings were observed:

1. Fire Check doors are not installed as per Gazette Notification dated 27.05.2019.
2. Pump found not in auto start provision.
3. The guest house building is comprised of ground, mezzanine and three upper floor and in building plan guest rooms have been shown at third floor also. As building having mezzanine floor, it is counted as floor, accordingly third floor is not allowed as per GN 27.05.2019. Therefore, an undertaking regarding not to use third floor for any purpose is required to be submitted.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.