

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

Dated. 06.10.2023

No. F.6/DFS/MS/GH/2023/SZ/256  
To

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Hotel Castle Blue, at Plot No A-109, Road no 5,  
Mahipalpur Extn. New Delhi-110037


Sir,

This is in reference with MHA Portal ID 2022082716702 dated 27/08/2022 on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 31/05/2023 in the presence of Mr. Rajesh Kumar of the Guest House. During the inspection, it was observed that the guest house is running at Ground + 03 Upper Floor. The shortcomings observed are as below,

1. Smoke management system provided but found not functional.
2. Carbon Monoxide detector is provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

