

C-31



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/261
To

Dated: 06.06.2023

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Hotel Classic Park, E-52, Near Corporation Bank,
Vasant Kunj Road, Mahipalpur, New Delhi 110037

Sir,

This is in reference with MHA Portal ID No 2023051508942 dated 19/05/2023 on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 31/05/2023 in the presence of Mr. Anil Kumar (Manager) of the Guest House. During the inspection, it was observed that the guest house is running at Ground + 03 Upper Floor. The shortcomings observed are as below;

1. Smoke management system not provided as per clause 7.31 of IJRR 2016
2. Carbon Monoxide detector is not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

**(ATUL GARG)
DIRECTOR**

DELHI FIRE SERVICE