

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2023/SZ/255

Dated 06/06/2023

To

The Joint Commissioner of Police / Lic-Branch
1st floor, Police Station,
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s LA-Sapphire Hotel, located at A-23,
Road no 1, Mahipalpur Extn. New Delhi-110037

Sir,

This has reference to with MHA Portal ID 2023032204032 dated 23/03/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28/05/2023 to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Fire check doors not provided as per clause 7.31 of UBBL 2016.
- 2 Smoke management system not provided in the upper floor as per clause 7.31 of UBBL 2016.
- 3 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

