DATED: 06/06/2023

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELIII HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2023/300

To,

The Principal,

Nirmal Bharatia Sr. Sec. School (Nirmal Society of Education)

Sector - 14, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Nirmal Bharatia Sr. Sec. School (Nirmal Society of Education) Located at Sector – 14, Dwarka, New Delhi.

Sir.

Please refer to your letter No. NiBS/Fire/Safety/2023/001, dated 18/05/2023 on the subject cited above. In this connection it is to inform to you that the above said building has been re-inspected by the officers concerned of this department on 29/05/2023 in presence of Sh. Jatinder Sharma (Employee) frpm fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

- Six m internal road around the building found encroached.
- 2. Fire check doors found removed at some places.
- Smoke management system is inadequate and not interlinked with MOEFA.
- Manually operated fire alarm system (MOEFA) found nonfunctional.
- 5. Public address system found nonfunctional.
- 6. Automatic sprinkler system found nonfunctional in basement.
- Branches and hoses found missing at some place.
- Main pump of 2280 lpm jockey pump of 180 lpm and standby pump of 2280 lpm at ground level not seen at site during the visit.
- Terrace pump found nonfunctional in auto mode.
- Underground fire water tank not seen at site during the visit.
- 11. Exit signage found removed at some places.
- 12. Communication system in lift car found nonfunctional.
- Pressurization of Lift Shaft & lift lobby found removed.

In view of the above, renewal of fire safety certificate cannot be considered. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretarian New Delhi-110054