



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/Club/2023/SZ/ 1176

Dated 05/06/2023

To

The Joint Commissioner of Police,
Lic Unit, 1st Floor, P S Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Sarva Priya Club, (Sarva Priya Cooperative House Building Society Ltd) Road No 2, Temple complex, Sarva Priya Vihar, New Delhi-110016

Sir,

This has reference to with MHA Portal ID 2023041206265 dated 03/05/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28/05/2023 to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 First aid hose reel provided but found not functional
- 2 Sprinkler system provided but found not functional
- 3 Internal hydrant system provided but found not functional
- 4 Terrace level fire fighting pumps provided but found not functional

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

slit