

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2023/SZ/252

Dated 06/06/2023

To

The Joint Commissioner of Police
Lic./ Branch, 1st floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s V. M. Residency Guest House located at 50, Main Road, Massood Pur, New Delhi 110070

Sir,

This has reference to with MHA Portal ID 2023041706603 Dated: 17/04/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31/05/2023 in the presence of Sh. Ravi Kumar to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. Smoke Management system not provided in the building as per clause 7.31 of UBBL 2016
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE