



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/294

Dated: 05/06/2023

To

The Principal
Lilawati Vidya Mandir Sr. Sec. School
Shakti Nagar, Delhi-110007.

Sub: - Regarding issuance of fire safety certificate in r/o Lilawati Vidya Mandir Sr. Sec. School (New Building) at Shakti Nagar, Delhi-110007.

Sir,

This has reference to your letter no. 6078/LVM dated 12.05.2023 received in this department vide outdoor dairy no.1911 dated: 12.05.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.05.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of new building, basement, ground & 04 upper floors only. At the time of inspection Smt. Sangeeta Sharma (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The width of 06m internal road and 09m on turning radius at two sides is obstructed by erecting a temporary tin shed and one temporary guard room constructed at entrance of entry gate. Needs to be removed.
2. Fire extinguisher provided but found not functional at the time of inspection.
3. Hose reel hose provided but not functional.
4. Internal hydrant provided but not functional.
5. Electrical Driven Fire Pump capacity of 2280lpm., & one diesel engine driven pump of similar capacity and Jockey Pump 180lpm and terrace level firefighting pumps capacity of 900lpm provided but found not functional.
6. Exit signage and floor signage found removed at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Gaba)
Director
Ph:-011-23114000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.