

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/2023/246

Dated: 05.06.2023

To

The Manager,
M/S **Metropolis Tourist Home Guest House**,
1624-27-34 & 35, Main Bazar, Pahar Ganj,
New Delhi.

Sub: Regarding grant of FSC in r/o M/S Metropolis Tourist Home Guest House, located at 1624-27-34 & 35, Main Bazar, Pahar Ganj, New Delhi.

Sir,

This has a reference to online ID No. 2023051208817 dated 13.05.2023, on the subject cited above. It is to inform you that the site was visited by the officers concerned of this department on dated 23.05.23 in presence of Manager and following shortcomings were observed: -

- 1) Fire check doors are not provided as per gazette notification 27.05.2019.
- 2) CO detectors are not provided as per gazette notification 27.05.2019.
- 3) Hose reel found nonfunctional.


Further, no. of rooms mentioned in the application form at second and third floor is 4nos at floor, whereas in the building plan 6 & 5 nos room are shown at each floor respectively. So, please clarify the use of others room.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to submit the compliance of the shortcoming at the earliest for further consideration in the matter.

Yours faithfully


(Anil Garg)
DIRECTOR

Delhi Fire Service


25/5

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police
Station, New Delhi.