



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/FH/2023/SZ/ 1202

Dated - 07/06/2023

To

Mr. Ankit Waghwa,
Divine Farm House, at Khasra No 309/4, 320, 321,
Village Sahoorpur, Tehsil Hauz Khas, New Delhi

Sub: - Regarding issuance of fire safety certificate in r/o Divine Farm House, at Khasra No 309/4, 320, 321, Village Sahoorpur, Tehsil Hauz Khas, New Delhi


Sir,

This has reference to with letter received through outdoor diary no 11487 dated 20/02/2023 the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28/05/2023 in the presence of Mr. Tapan Singh to verify the fire safety measures installed in the building. During inspection, following points were observed

1. First Aid hose reel provided but found not functional.
2. Internal and yard hydrant provided but found not functional.
3. Fire fighting pumps provided but found not functional.
4. Exit signage's found removed at some places.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

0/11