

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/NDZ/2023/ 1206

Dated: 09/06/2023

To,

Sh. Jai Prakash Sharma,
Dy. Director (Genl),
Headquarter's Office ESIC,
Panchdeep Bhawan, CIG Marg,
New Delhi.

Sub:- Regarding renewal of FSC in r/o Headquarter's Office Employees State Insurance Corporation, Panchdeep Bhawan, CIG Marg, New Delhi.

Sir,

This has reference to your letter no. D-14012/3/2022-GEN dated 19/05/2023, on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 01/06/2023 in the presence of Sh. Dinesh (Asst. Director) and the following shortcomings were observed:-

1. Additional staircase/exit is not provided to gym/ recreation room at first floor.
2. Electrical shafts are not sealed properly at floor level
3. Detectors found nonfunctional at some offices.
4. Lift signages "not to use lift in case of fire" are not provided.

In view of above shortcomings, request for issuance of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service