

C 22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/BNQT/2023/SZ/ 141

Dated: 06/06/23

To,

Sh. Sourabh Gandhi (Owner),
M/s Kangna Banquets, Plot No. 1, 2 & 5, Z- Block Extn.,
Main Najafgarh Road, Uttam Nagar, New Delhi-110059.

Sub: -Regarding issuance of Fire Safety Certificate in r/o M/s Kangna Banquets, Plot No. 1, 2 & 5, Z- Block Extn., Main Najafgarh Road, Uttam Nagar, New Delhi-110059.

Sir,

This has reference to Outdoor diary No. 2072 dated 18/05/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Sh.Saurabh Gandhi was present and it was observed that the building is comprised of ground plus three upper floors but banquet running at ground floor only and have following shortcomings:-

1. Second Staircase having width 1.40 m provided instead of 150 m.
2. Fire Check doors not provided.
3. Hose reel system provided but not functional
4. Detection system provided but not functional.
5. MOEFA provided but not functional.
6. Public Address System provided but not functional.
7. Internal hydrant system provided but not functional.
8. Fire pumps are not installed.
9. Overhead water tank found empty.
10. Exit signage's are not sufficient.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours Faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

The Joint Commissioner of Police,
Licensing Unit, Office of the Joint Commissioner of Police,
1st Floor, Police Station, Defence Colony, New Delhi.

BIC
P K