

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/CNG/NDZ/2023/ 1180

Dated: 06/06/2023

To

Sh. Ajay Khatri  
DGM (Fire & Safety), IGL Bhawan,  
Plot No. 4, Community Centre,  
R.K. Puram Sec-9, New Delhi-22.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Metcalfe House CNG Station, Delhi.

Sir,

This has reference to letter no IGL/F&S/2023/15/17/1 dated 15.05.2023 on the subject cited above. It is to inform you that the CNG Station was inspected by the officer concerned of this department on 29.05.2023 in the presence Mr. Anil (Manager) and it was observed that the owner/ occupier have been partially complied the shortcomings issued vide letter no. F.6/DFS/MS/CNG/NDZ/2023/614 dated 24.03.2023 except following which are still exists:-

1. "No Smoking" sign board not provided.
2. Foam trolley found not working.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
01  
8/6  
02/6