

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Dated 08/06/2023

No. F.6/DFS/MS/2023/SZ/ 1189

To,  
The Authorized Signatory,  
Laxmi Buildtech Pvt Ltd,  
Plot No. D-1 & P3A, Saket District Centre,  
Saket, New Delhi-110017

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No. D-1 & P3A, Saket District Centre, Saket, New Delhi-110017

Sir,  
This has reference with your letter received through outdoor diary no 1779 dated 09/05/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 31/05/2023 in the presence of Mr. Rajender Kumar and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Ventilation system in the basement found not functional
2. Automatic sprinkler system found removed at some places in the building.
3. Automatic fire detection system found removed at some places in the building.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
