

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2023/ 1188

DATED: 08/06/2023

To,

The Authorized Signatory,  
 Sri Durga CGHS Ltd  
 Plot No.06A, Sector-11, Dwarka,  
 New Delhi - 110075.

**Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Sri Durga CGHS Ltd Located at Plot No.06A, Sector-11 , Dwarka, New Delhi - 110075.**

Sir,

This is in reference to your letter No. SDCGHSI/Fire-System/2023-24/01, dated 17/05/2023 on the subject cited above. In this connection it is to inform to you that the above said premises was re-inspected by the officer concerned of this department on 31/05/2023 in the presence of Sh. Sanju (Manager) from fire safety point of view

**During the course of inspection followings shortcoming have been observed:-**

1. Six meter wide internal road around the building found encroached.
2. Hose reel hose & hydrant found nonfunctional.
3. MOEFA found nonfunctional.
4. Public Address System found nonfunctional.
5. Terrace pump found nonfunctional.
6. The main valves of terrace pump were kept closed.
7. Overhead water tank of capacity 25,000 ltr found empty.
8. Exit Signage found removed at some places.
9. Dully filled form J & K are not submitted.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.


Yours faithfully,

  
 (Atul Garg)  
 Director

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.

  
 08/06/23