

C-28



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/301

Dated: 07/06/2023

To
The Manager
Govt. Girls Secondary School
Haiderpur, Delhi-110088.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Girls Secondary School (School ID No.1309024) located at Haiderpur, Delhi-110088.

Sir,

Please refer to your letter No. HP/GGSS/23/171 dated 09.05.2023 received in this department vide outdoor dairy no.1858 dated: 11.05.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 25.05.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor only. At the time of inspection Sh. Virender (Estate Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher provided but not functional at the time of inspection.
2. Exit signage and floor signage found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Handwritten signature)
 (Atul Garg)
 Director
 Ph: 011-23414000
(Handwritten initials)

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.