



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

633
7-2
आज की
समस्या का
समाधान

No. F6/DFS/MS/2023/WZ/ 310

Dated:- 12/06/2023

To,

The Principal,
Khalsa Convent School,
B-18, Ranjeet Vihar, Nilothi,
New Delhi-110041.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Khalsa Convent School Located at B-18, Ranjeet Vihar, Nilothi, New Delhi-110041.

Sir,

This has reference to your email dated 12.04.2023 on the subject cited above. In this connection, it is to inform you that the said school building was re-inspected by the officer concerned of this department on 30.05.2023 in the presence of Sh. Gaurav (Security Guard).

During the inspection, it was observed that the building is comprised of Ground + 02 Upper Floors. Fire Safety arrangements such as fire extinguishers, first aid hose reel, & Overhead water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. First aid hose reel found non-functional.
2. Fire pump of 220 lpm found non-functional.
3. Overhead water storage tank found reduced to 2,000 ltrs capacity against required of 5,000 ltrs capacity.
4. One room constructed at terrace shall be removed.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.