



225

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2023/NDZ/ 315

Dated 13/06/2023

To,

The Ex. Engineer (Elect.)-II
MCD Office of the Executive Engineer (Elect.)-II/SSZ
2nd Floor, Technical Laboratory, Near NH-24
Gazipur, Delhi-110096

Subject: - Regarding Issuance of Fire Safety Certificate in r/o MCD Primary School at Radhey Puri, Delhi-110051.

Sir,

This is in reference to your email letter No. E.E (Elect.)-II/Shah(S)/2023-2024/D-70 dated 02/05/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 20/05/2023 in presence of Mr. Chirag, Contractor of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. Overhead water storage tank capacity 10,000 liters not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002
2. MCD Primary School
Radhey Puri, Delhi-110051.