



C 29

75
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2023/NDZ/ 314

Dated 13/06/2023

To,

The Executive Engineer(Elect.)-II/SSZ
Municipal Corporation of Delhi
Office of Executive Engineer (Elect.)_II/SSZ
2nd floor, technical Laboratory Near NH-24, Ghazipur, Delhi-110096

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Pimary CoEd. School located at West Azad Nagar, Shahdara South, Delhi- 110051.

Sir,

This is in reference to your letter No. E.E.(Elect.)-II/Shah(S)/2023-2024-D-18 dated 17/04/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of J.E. (Elect.). The following points / shortcomings were noticed in the building which is comprised of ground plus three upper floors and two separate block of ground plus one & ground plus three.

1. One additional staircase of width 1.50 meter is required in the building.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(ATUL GARG)

**DIRECTOR
DELHI FIRE SERVICE**

Copy to:-

- 1.The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002
- 2.The Principal,
Nigam Pimary CoEd. School,
West Azad Nagar, Shahdara South, Delhi- 110051