

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO F-6/DFS/MS/EH/2023/SZ/308

Dated 09/06/2023

To

The Dy. Health Officer, MCD,
Public Health Officer, Central Zone,
Jal Vihar, Lajpat Nagar,
New Delhi 110024

Sub: - Regarding issuance of fire safety certificate in r/o M/s **Only Bar Restaurant** (unit of White Paper Designs Pvt Ltd) at First Floor, 24, Rajlok Building, Nehru Place, New Delhi 110019

Sir,

This has reference to with MHA Portal 2023041306408 dated 13/04/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.06.2023 in the presence of Mr. Abhishek Bansal to verify the fire safety measures installed in the building and observed that restaurant running at First floor of the building comprised of Basement, ground plus 05 upper floors. During inspection, following points were observed:

- 1 First aid Hose reel provided but found not functional.
- 2 The Internal Hydrant provided but found not functional.
- 3 Terrace level Fire Pump capacity of 450 LPM provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to -

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.